

**ADDENDUM NO. 3
TO THE
BIDDING DOCUMENTS FOR
WASTEWATER TREATMENT PLANT IMPROVEMENTS
CITY OF DYSART, IOWA
AECOM #60598068**

Date: February 4, 2022

Bids Close: February 9, 2022; 4:00 p.m. (Date Revised per Addendum No. 1 - 01/04/2022)

TO ALL BIDDERS ON THE ABOVE PROJECT:

All Bidders submitting a bid on the above contract shall carefully read this Addendum and give it consideration in the preparation of their bid.

I. The following edits are being made to the TECHNICALS:

- A. Technical **40 05 31 MANUALLY ACTUATED VALVES AND CHECK VALVES**. On page 3 of this Technical, please **insert** a new Section 2.05 BUTTERFLY VALVES - AERATION SERVICE as shown below.

"2.05 BUTTERFLY VALVES – AERATION SERVICE

"A. Butterfly valves for the aeration of the lagoon and within the blower building.

1. Manufacturers:

- a. DeZurik.**
- b. Engineer approved equivalent.**

2. Body:

- a. Wafer-lug type with full-lug body, drilled and tapped for mounting bolts design.**
- b. Material: ASTM A126 cast iron.**
- c. Provide to mate with 125-pound ANSI B16.1 (Class 125 flanges).**

3. Seat:

- a. Dovetail, Buna-N/EPDM, installed in the body with elastomer formed continuously over the ends to provide seal with mating pipe flanges.**
- b. EPDM Temperature Range: -30 degree F to 140 degree F equivalent.**

4. Disk:

- a. Air profile design, CF8M Type 316 stainless steel.**
- b. Provide bubble-tight shut off at 25 psi working air pressure.**

5. Stem:

- a. Disc Stem connection: 12-inch and smaller: Type 410 stainless steel torque plug.**

6. Valve Operators:

- a. Manually operated valves 12-inch and smaller provide lever-type with 10-position lock plate and valve position indicator.**

7. Pin: Carbon Steel
8. Hand Lever: Malleable Iron
9. Name Plate: Aluminum Plate
10. Position: Carbon Steel

- B. With insertion of the new Section 2.05, please **renumber the previous Section 2.05 to Section 2.06**. There are no other edits made to the newly numbered Section 2.06.
- C. Technical 40 05 31 is not being included as an attachment but is made a part of this Addendum No. 3. The above information should be considered "**call-out**" edits for your reference.

II. Attachments: None

III. Any revisions to any of the Contract Documents made by this Addendum shall be considered as the same revision to any and all related areas of the Contract Documents not specifically called out in this Addendum.

IV. The Bidder shall acknowledge receipt of this Addendum by inserting the date and number in the spaces provided on page 1 of the **revised Bid Form, marked "Revised Per Addendum No. 2 - 02/02/2022."** The revised Bid Form was provided previously as an attachment to Addendum No. 2. Failure to use the appropriate **revised Bid Form** and failure to insert the appropriate Addendum No. and Dates for any and all Addenda issued on this project could cause your submittal to be considered unresponsive.



Ross Hillsman, PE
Project Manager / AECOM